



NOTES:

1. WHERE RISER DOES NOT PASS THROUGH A ROOF OVERHANG, A SECOND PIECE OF UNISTRUT MUST BE INSTALLED JUST BELOW ROOF LINE. SEE DRAWING NO. S-787.
2. THE DEPARTMENT WILL NOT BE RESPONSIBLE FOR ANY DAMAGE TO THE BUILDING CAUSED BY RAIN OR STRUCTURAL FAILURE.
3. CONTRACTOR MUST LEAVE 3' OF WIRE OUT OF THE SERVICE HEAD.
4. ATTACHMENT POINT MUST BE ACCESSIBLE BY LADDER. SEE BWP DRAWING S-714.
5. CONTRACTOR MUST NOTIFY BWP OF ANY CHANGES MADE AFTER CONFIRMATION OF SERVICE THAT WOULD AFFECT SERVICE ATTACHMENT (ROOFLINE, ROOFING MATERIAL, WORKSPACE, ETC.).
6. ELECTRICAL SERVICE EQUIPMENT MUST HAVE A MIN. 3' LATERAL CLEARANCE FROM ANY GAS LINE.
7. NO 120 VOLT LOAD SHALL BE CONNECTED ON 240 VOLT OR 480 VOLT 3-PHASE DELTA SERVICES.

						BURBANK WATER AND POWER – ELECTRIC SERVICES	
						PERISCOPE SERVICE COMMERCIAL 100, 200 AMP PANEL INSTALLATION WITH EAVE	
B	STANDARDIZED FORMATTING	MEP	CJC	5/9/23			Sheet 1 of 1
A	REMOVE NOTE	SP	RS	2/14/18			
No.	REVISIONS	BY	APPR'V'D	DATE			