


NOTES:

1. BWP WILL NOT BE RESPONSIBLE FOR ANY DAMAGE TO THE BUILDING CAUSED BY RAIN OR STRUCTURAL FAILURE.
2. THE RISER SHALL BE ON OR NOT MORE THAN 18" BACK OF THE FRONT FACE OF THE WALL FACING BWP'S POLE LINE.
3. CONTRACTOR MUST LEAVE 3' OF WIRE OUT OF THE SERVICE HEAD.

F	STANDARDIZED FORMATTING	MEP	CJC	5/9/23	 WATER AND POWER	BURBANK WATER AND POWER – ELECTRIC SERVICES	
E	REDRAWN IN AUTOCAD	DSL		7-12-04		PERISCOPE SERVICE RESIDENTIAL INSTALLATION WITHOUT EAVES	DRAWING No.
D	ADDED CONCRETE WORK PAD	TZ	FCF	12-30-92			S-402F
C	CHANGED MINIMUM CONDUIT SIZE	TZ	DDB	7-24-87			
No.	REVISIONS	BY	APPR'V'D	DATE			