

Burbank Operable Unit Treatment Facility

Well samples

DATE	W110		W120		W130		W140		W150		W160		W170		W180	
	Cr	Cr6	Cr	Cr6	Cr	Cr6	Cr	Cr6	Cr	Cr6	Cr	Cr6	Cr	Cr6	Cr	Cr6
Oct-99	30	16	20	6	20	11	ND	3	10	6	10	ND	ND	3	ND	ND
Nov-99	30	23	ND	6	20	9	10	5	20	9	20	9	10	2	10	4
Dec-99	40	21	10	5	20	11	10	4	10	9	10	6	ND	2	ND	5
Jan-00	20	ND	10	3	10	4	10	2	10	4	10	3	ND	4	10	3
Feb-00	20	16	ND	8	ND	3	10	9	10	5	ND	ND	ND	3	ND	ND
Mar-00	30	30	1	8	ND	4	ND	2	ND	5	ND	2	ND	ND	ND	2
Apr-00	20	9	ND	3	ND	ND	ND	6	ND	8	ND	6	ND	ND	ND	4
May-00	30	5	ND	2	10	8	10	9	ND	4	ND	8	ND	2	ND	ND
Jun-00	3	10	1	7	1	8	1	4	OOS	OOS	ND	8	ND	3	ND	4
Jul-00	ND	8	ND	7	ND	3	ND	4	OOS	OOS	ND	7	ND	ND	ND	4
Aug-00	20	16	10	6	ND	5	ND	5	ND	8	ND	2	ND	ND	ND	4
Sep-00	50	52	ND	7	8	8	ND	8	10	11	ND	8	OOS	OOS	ND	3
Average	24	17	4	6	7	6	4	5	7	7	4	5	1	2	2	3

Maximum Contaminant
Level (MCL), parts per billion (ppb)

State Federal
Cr 50 100 Total Chromium
Cr6 Unregulated Hexavalent Chromium

ND Non-Detect
OOS Out of Service
NA Not Analyzed

Note: EPA test method 200.7 has a DLR of 10 ppb.
EPA prep-method 7195 was add to analysis method
200.7 to achieve a DLR Of 2 ppb for Cr6