

Lake St. GAC Treatment Facility

Date	WELL # 7		WELL # 15		PLANT EFFLUENT							
	Cr	Cr6	Cr	Cr6	Cr	Cr6						
Oct-99	12.4	14	18.9	15	15.3	16						
Nov-99	Plant Offline											
Dec-99												
Jan-00												
Feb-00												
Mar-00	Plant Offline											
Apr-00							6.5	ND	6.8	ND	0.4	ND
May-00							ND	ND	16.2	10	10.5	ND
Jun-00							ND	ND	13.9	ND	10.4	ND
Jul-00	ND	ND	41	40	10.5	10						
Aug-00	OOS	OOS	15.6	13	ND	ND						
Sep-00	PD	PD	PD	PD	PD	PD						
Average	3	2	19	13	8	4						

Maximum Contaminant Level (MCL), parts per billion (ppb)

	State	Federal	
Cr	50	100	Total Chromium
Cr6	Unregulated		Hexavalent Chromium

ND Non Detect
OOS Out of Service
NA Not Analyzed
PD Pending Analytical Result

Note: Chromium samples are collected monthly, Plant Effluent is located at point of entry into water distribution system. EPA test method 200.8 with a DLR of 10 ppb.