



NOTES:

1. PRIOR TO INSTALLATION, CONTACT BURBANK WATER AND POWER INSPECTOR AT (818) 238-3590 TO SCHEDULE INSPECTION AT LEAST 48 HOURS IN ADVANCE.
2. IF THE REQUIRED SAFETY CLEARANCE AROUND A SWITCH OR TRANSFORMER ABUTS A SOLID OBSTRUCTION, THE SAFETY CLEARANCES SHALL BE INCREASED BY 2 FEET.

					BURBANK WATER AND POWER – ELECTRIC SERVICES		
B	ADDED NOTE 2	MEP	SK		9/26/23	SWITCH & (2) TRANSFORMER PADS REQUIRED CLEARANCES ORIENTATION PLAN No. 3	DRAWING No.
A	STANDARDIZED FORMATTING/UPDATE CLEARANCES	MEP	CJC		5/9/23		S-605B
	NEW DRAWING	MJK	GLS		8/26/96		
No.	REVISIONS	BY	APPR'V'D		DATE		Sheet 1 of 1