


City of Burbank



ND = Non Detectable



Cr Sample Sites 2007-06a1 7-02-07 TPL

Chromium Sample Sites

COLLECTED JUNE 12, 2006

CHROMIUM TESTING

SAMPLING EVENT OF June 12 2007

The City Council requested that total chromium and chromium 6 test results be obtained for various public buildings in Burbank. Samples were collected on June 12, 2007. Truesdail Laboratories analyzed the samples and the results are shown below. The minimum detection limit used for total chromium under test method EPA 200.8 is 1 ppb; EPA test method 218.6 for chromium 6 uses a detection limit of 1 ppb.

The California Department of Health Services maximum contaminate level (MCL) for total chromium is 50 parts per billion (ppb). Total chromium is the sum of chromium 3 and chromium 6. There is no MCL for chromium 6 at this time.

SAMPLE LOCATIONS

Location	Address	April 2007		June 2007	
		Total Chromium	Hex. Chromium 6	Total Chromium	Hex. Chromium 6
City Hall	275 East Olive Ave.	3	2	2	2
Main Library	110 North Glenoaks Blvd.	2	2	ND	ND
Buena Vista Library	401 North Buena Vista St.	3	2	2	2
Northwest Library	3323 West Victory Blvd.	3	2	2	2
Joslyn Center	1301 West Olive Ave.	3	2	2	2
Fire Station No. 13	2713 Thornton Ave.	3	2	2	2
Fire Station No. 12	664 North Hollywood Way	3	3	2	2
Burbank High School	902 North Third St.	3	3	2	2
John Burroughs High School	1920 Clark Ave.	3	3	2	2
John Muir Middle School	1111 North Kenneth Rd.	3	3	ND	ND
Robert L. Stevenson Elementary School	3333 Oak Street	3	3	2	2
William McKinley Elementary School	349 West Valencia Ave	2	2	ND	ND