



NOTES:

1. WHERE RISER DOES NOT PASS THROUGH A ROOF OVERHANG, A SECOND PIECE OF UNISTRUT WILL BE INSTALLED JUST BELOW ROOF LINE. SEE DRAWING NO. S-402.
2. BWP WILL NOT BE RESPONSIBLE FOR ANY DAMAGE TO THE BUILDING CAUSED BY RAIN OR STRUCTURAL FAILURE.
3. CONTRACTOR MUST LEAVE 3' OF WIRE OUT OF THE SERVICE HEAD.
4. ATTACHMENT POINT MUST BE ACCESSIBLE BY LADDER, SEE DRAWING NO. S-714.
5. CONTRACTOR MUST NOTIFY BWP OF ANY CHANGES MADE AFTER CONFIRMATION OF SERVICE THAT WOULD AFFECT SERVICE ATTACHMENT (ROOFLINE, ROOFING MATERIAL, WORKSPACE, ETC.).
6. ELECTRICAL SERVICE EQUIPMENT MUST HAVE MINIMUM 3' LATERAL CLEARANCE FROM ANY GAS LINE.

H	STANDARDIZED FORMATTING AND ADDED DETAIL B	MEP	CJC	5/9/23	<p>CITY OF BURBANK WATER AND POWER</p>	BURBANK WATER AND POWER – ELECTRIC SERVICES	
G	LIMIT RISER HEIGHT	SP	RS	11/30/17		<p>PERISCOPE SERVICE RESIDENTIAL</p>	DRAWING No.
F	LADDER ACCESS SUPPORT	SRA	CA	1/16/16			<p>S-401H</p>
E	UPDATED REQUIREMENTS	DSL	DDB	2/9/06			
No.	REVISIONS	BY	APPR'V'D	DATE		Sheet 1 of 1	