



**NOTES:**

1. BURBANK WATER AND POWER WILL EXCHANGE BOTH OF THE CONTRACTOR'S COUPLINGS FOR COUPLINGS WITH THREADED STUDS, PRIOR TO INSTALLATION.
2. PRIOR TO INSTALLING, CONTACT BURBANK WATER AND POWER CONDUIT MECHANIC/INSPECTOR AT (818) 238-3582 TO SCHEDULE INSPECTION AT LEAST 24 HOURS IN ADVANCE.
3. THE CONTRACTOR MUST INSTALL THE GROUND RODS AND GROUNDING SYSTEM CALLED FOR IN THIS STANDARD WHILE IN THE PRESENCE OF THE BWP INSPECTOR AND TO THE SATISFACTION OF THOSE REQUIREMENTS DETAILED IN THE LATEST VERSION OF THE NATIONAL ELECTRICAL CODE, ARTICLES 250-83 AND 250-84.
4. REFER TO DRAWING S-821 FOR GROUNDING DETAILS.

G	STANDARDIZED FORMATTING	MEP	CJC	5/9/23
F	REVISED NOTES	PL	DDB	2/07/03
E	REDRAWN IN AUTOCAD	WAW	GLS	10/10/97
D	REVISED NOTE	TZ	DDB	5/14/91
No.	REVISIONS	BY	APPR'V'D	DATE



<b>BURBANK WATER AND POWER – ELECTRIC SERVICES</b>	
<b>PRIMARY RISER POLE GROUNDING REQUIREMENTS</b>	DRAWING No. <b>S-461G</b>
Sheet 1 of 1	